

11/3/2021

Monthly Water Report

9:38 AM

Date	Oct-21																			
Water Plant																				
Total Gal.>	4,803,500	Max	292,500	Min	61,700	Avg	155,000	Gpm	253											
Total Hrs.>	316.4	Max	18	Min	4.5	Avg	10.2064516													
Last Month.>	4,841,600	Max	220,800	Min	124,100	Avg	161,400	Gpm	247											
Last Year.>	4,344,100	Max	187,300	Min	68,300	Avg	140,100	Gpm	240											
Lbs. of Chlorine 691 Lbs of Fluoride 51 Gallons of salt brine 2,684																				
Chlorine.Mg/l 0.74 Fluoride.Mg/l 0.5 Hardness. Mg/l 95 Iron. Mg/l 0.01 Nitrate.Mg/l																				
Well																				
Date	10/21/2021																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	28	22	6	110																
Well # 9	34	22	12	100																
Well # 10	24	6	18	100																
Well # 11	28	10	18	230																
Water Meters																				
	New Installs			Read In																
	Replace Meter			Read Out																
	Replace Radio Read			Shut off For nonpayment																
	Repair																			
Fire Hydrants																				
	New Install			Flush Hyd		Repair Hyd														
Water Plant																				
	10/26/2021 - Took iron filters off line for replacement.																			
Water Tower																				
Reservoir																				
	10/18/2021 - Installed new dialer at Reservoir. Work done by Jetco.																			
Dist. System																				
Wells																				
	10/21/2021 - Tested wells 7-9-10-11 no issues.																			
Other																				