

10/8/2021

Monthly Water Report

2:31 PM

Date	Sep-21															
Water Plant																
Total Gal.>	4,841,600	Max	220,800	Min	124,100	Avg	161,400	Gpm	247							
Total Hrs.>	328.5	Max	15.4	Min	8.6	Avg	10.95									
Last Month.>	4,682,000	Max	245,000	Min	45,000	Avg	151,000	Gpm	300							
Last Year.>	4,791,400	Max	272,000	Min	96,000	Avg	159,700	Gpm	241							
Lbs.of Chlorine 752 Lbs of Fluoride 43 Gallons of salt brine 3,788																
Chlorine.Mg/l	0.81	Fluoride.Mg/l	0.5	Hardness. Mg/l	98	Iron. Mg/l	0.02	Nitrate.Mg/l								
Well																
Date	9/28/2021															
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	30	22	8	120												
Well # 9	34	24	10	100												
Well # 10	22	8	14	90												
Well # 11	26	10	16	230												
Water Meters																
	New Installs			Read In												
	Replace Meter			Read Out												
	Replace Radio															
	Read			Shut off For												
	Repair			nonpayment												
Fire Hydrants																
	New Install			Flush Hyd				Repair Hyd								
Water Plant																
	9/30/21 - backwashed iron filters 1-2-3															
Water Tower																
Reservoir																
Dist. System																
Wells																
	9/28/21 - Tested wells 7-9-10-11 no issues															
Other																