

1/6/2022

Monthly Water Report

9:36 AM

Date	Dec-21																			
Water Plant																				
Total Gal.>	3,892,700	Max	161,600	Min	93,500	Avg	125,600	Gpm	253											
Total Hrs.>	257.4	Max	11.7	Min	6.3	Avg	8.3													
Last Month.>	3,835,700	Max	163,500	Min	102,300	Avg	127,900	Gpm	255											
Last Year.>	4,636,900	Max	256,000	Min	85,700	Avg	149,600	Gpm	245											
Lbs.of Chlorine 572 Lbs of Fluoride 42 Gallons of salt brine 3,355																				
Chlorine.Mg/l 0.82 Fluoride.Mg/l 0.6 Hardness. Mg/l 115 Iron. Mg/l 0.02 Nitrate.Mg/l																				
Well																				
Date	12/21/2021																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	30	14	16	120																
Well # 9	32	14	18	80																
Well # 10	30	12	18	100																
Well # 11	30	10	20	230																
Water Meters																				
	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio				Shut off For nonpayment															
	Read																			
	Repair																			
Fire Hydrants																				
	New Install				Flush Hyd				Repair Hyd											
Water Plant 12/10/2021 - New iron filters placed inservice.																				
Water Tower																				
Reservoir																				
Dist. System																				
Wells 12/21/2021 - Tested wells 7-9-10-11. No issues																				
Other																				