

3/2/2022

Monthly Water Report

12:05 PM

Date	Feb-22																			
Water Plant																				
Total Gal.>	4,295,600	Max	279,500	Min	110,100	Avg	153,400	Gpm	251											
Total Hrs.>	290.7	Max	21	Min	6.8	Avg	10.4													
Last Month.>	2,023,700	Max	307,100	Min	0	Avg	65,300	Gpm	110											
Last Year.>	5,110,900	Max	272,600	Min	141,300	Avg	182,500	Gpm	241											
Lbs.of Chlorine 636 Lbs of Fluoride 41 Gallons of salt brine 7,284																				
Chlorine.Mg/l 0.84 Fluoride.Mg/l 0.8 Hardness. Mg/l 96 Iron. Mg/l 0.02 Nitrate.Mg/l																				
Well																				
Date	2/8/2022																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	26	10	16	130																
Well # 9	30	12	18	120																
Well # 10	32	10	22	120																
Well # 11	28	10	18	240																
Water Meters																				
	New Installs			Read In																
	Replace Meter			Read Out																
	Replace Radio Read			Shut off For nonpayment																
	Repair																			
Fire Hydrants																				
	New Install			Flush Hyd		Repair Hyd														
Water Plant																				
Water Tower																				
Reservoir																				
Dist. System	2/7/22 - 4" water main break in the 100 block of 15th St. 2/18/22 - 4" water main break at Percival & Laurel 2/24/22 - 4" water main break at Hatton & Linden 2/25/22 - 4" water main break at Hatton & Sycamore																			
Wells	2/8/2022 - Tested Wells 7-9-10-11 no issues																			
Other																				