

7/7/2022

Monthly Water Report

3:16 PM

Date	Jun-22																			
Water Plant																				
Total Gal.>	4,495,600	Max	210,300	Min	103,000	Avg	149,900	Gpm	257											
Total Hrs.>	293.2	Max	14.3	Min	6.2	Avg	9.8													
Last Month.>	4,772,400	Max	212,400	Min	72,000	Avg	141,000	Gpm	259											
Last Year.>		Max		Min		Avg		Gpm												
Lbs.of Chlorine 649 Lbs of Fluoride 42 Gallons of salt brine 7,265																				
Chlorine.Mg/l 0.57 Fluoride.Mg/l 0.6 Hardness. Mg/l 68 Iron. Mg/l 0.01 Nitrate.Mg/l																				
Well																				
Date	6/21/2022																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	28	12	14	110																
Well # 9	28	16	12	120																
Well # 10	32	10	22	110																
Well # 11	30	8	22	230																
Water Meters																				
	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio				Shut off For nonpayment															
	Read																			
	Repair																			
Fire Hydrants																				
	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
Water Tower																				
Reservoir																				
6/5/2022 - Inspection of reservoir done by Midco.																				
Dist. System																				
Wells																				
6/21/22 - tested wells 7-9-10-11 no issues																				
Other																				