

4/7/2022

# Monthly Water Report

1:15 PM

Date	Mar-22											
<b>Water Plant</b>												
Total Gal.>	4,228,200	Max	258,600	Min	47,100	Avg	136,400	Gpm	263			
Total Hrs.>	270.5	Max	15.8	Min	2.9	Avg	8.7					
Last Month.>	4,295,600	Max	279,500	Min	110,100	Avg	153,400	Gpm	251			
Last Year.>	3,962,300	Max	213,800	Min	74,500	Avg	127,800	Gpm	261			
Lbs.of Chlorine 718 Lbs of Fluoride 40 Gallons of salt brine 7,302												
Chlorine.Mg/l	0.92	Fluoride.Mg/l	0.8	Hardness. Mg/l	105	Iron. Mg/l	0.08	Nitrate.Mg/l				
Well												
Date	3/9/2022											
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	24	10	14	130								
Well # 9	30	12	18	130								
Well # 10	32	8	24	120								
Well # 11	28	8	20	240								
<b>Water Meters</b>												
	New Installs			Read In								
	Replace Meter			Read Out								
	Replace Radio			Shut off For								
	Read			nonpayment								
	Repair											
<b>Fire Hydrants</b>												
	New Install			Flush Hyd			Repair Hyd					
<b>Water Plant</b>												
	3/3/2022 -Backwashed Filters 1-2-3											
<b>Water Tower</b>												
<b>Reservoir</b>												
<b>Dist. System</b>												
	3/15/22 - Water main break just west of 2553 240th St. 6" main											
	3/17/22 - Water main break just east of 2553 240th St. 6" main											
<b>Wells</b>												
	3/9/22 - Tested wells 7-9-10-11 no issues											
<b>Other</b>												