

5/5/2022

Monthly Water Report

9:37 AM

Date	Apr-22																				
Water Plant																					
Total Gal.>	4,205,500	Max	317,700	Min	96,000	Avg	140,200	Gpm	265												
Total Hrs.>	267	Max	21.3	Min	5.4	Avg	8.9														
Last Month.>	4,228,200	Max	258,600	Min	47,100	Avg	136,400	Gpm	263												
Last Year.>	4,180,600	Max	194,800	Min	102,500	Avg	139,400	Gpm	257												
Lbs.of Chlorine	510	Lbs of Fluoride	38	Gallons of salt brine	547,174																
Chlorine.Mg/l	0.83	Fluoride.Mg/l	0.7	Hardness. Mg/l	94	Iron. Mg/l	0.01	Nitrate.Mg/l													
Well																					
Date	4/21/2022																				
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	
Well # 7	24	10	14	120																	
Well # 9	30	12	18	130																	
Well # 10	32	10	22	110																	
Well # 11	30	8	22	220																	
Water Meters		New Installs			Read In																
		Replace Meter			Read Out																
		Replace Radio			Shut off For nonpayment																
		Read																			
		Repair																			
Fire Hydrants	New Install			Flush Hyd			Repair Hyd														
Water Plant																					
Water Tower																					
Reservoir																					
Dist. System	4/24/2022 - Water main break just west of 2553 240th St. 6" main.																				
Wells	4/21/22 - Tested wells 7-9-10-11 no issues																				
Other																					