

9/7/2022

Monthly Water Report

9:11 AM

Date	Aug-22																			
Water Plant																				
Total Gal.>	4,881,800	Max	255,000	Min	52,300	Avg	157,500	Gpm	262											
Total Hrs.>	309.6	Max	17.3	Min	3.7	Avg	10.0													
Last Month.>	4,895,400	Max	249,500	Min	83,700	Avg	157,900	Gpm	254											
Last Year.>	4,682,000	Max	245,000	Min	45,000	Avg	151,000	Gpm	300											
Lbs. of Chlorine 623 Lbs of Fluoride 46 Gallons of salt brine 6,728																				
Chlorine.Mg/l 0.7 Fluoride.Mg/l 0.5 Hardness. Mg/l 88 Iron. Mg/l 0.01 Nitrate.Mg/l																				
Well																				
Date	8/11/2022																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	22	12	10	110																
Well # 9	26	10	16	110																
Well # 10	28	8	20	100																
Well # 11	30	8	22	220																
Water Meters																				
	New Installs			Read In																
	Replace Meter			Read Out																
	Replace Radio			Shut off For																
	Read			nonpayment																
	Repair																			
Fire Hydrants																				
	New Install			Flush Hyd			Repair Hyd													
Water Plant																				
	8/24/2022 - Installed new chlorine pump																			
Water Tower																				
Reservoir																				
Dist. System																				
Wells																				
	8/11/2022 -Tested wells 7-9-10-11 no issues																			
Other																				