

9/6/2023

## Monthly Water Report

3:27 PM

Date	Aug-23											
Water Plant												
Total Gal.>	4,541,300	Max	215,800	Min	90,500	Avg	146,494	Gpm	249			
Total Hrs.>	305.7	Max	13.7	Min	5.6	Avg	9.9					
Last Month.>	4,663,300	Max	259,900	Min	34,200	Avg	150,429	Gpm	232			
Last Year.>	4,881,800	Max	255,000	Min	52,300	Avg	157,500	Gpm	262			
Lbs.of Chlorine	325	Lbs of Fluoride	51	Gallons of salt brine	3,171							
Chlorine.Mg/l	0.81	Fluoride.Mg/l	0.6	Hardness. Mg/l	94.5	Iron. Mg/l	0.03	Nitrate.Mg/l				
Well												
Date	8/3/2023											
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	20	6	14	120								
Well # 9	22	10	12	100								
Well # 10	20	8	12	120								
Well # 11	28	6	22	230								
Water Meters	New Installs			Read In								
	Replace Meter			Read Out								
	Replace Radio Read			Shut off For nonpayment								
	Repair											
Fire Hydrants	New Install			Flush Hyd			Repair Hyd					
Water Plant												
Water Tower												
Reservoir												
Dist. System	8/30/2023 - Water main break South of 305 Kellogg in alley. 4" main - 16" piece cutout and replaced											
Wells	8/3/2023 - Tested Wells 7-9-10-11 no issues											
Other												