

1/6/2023

# Monthly Water Report

9:07 AM

Date	Dec-22																			
<b>Water Plant</b>																				
Total Gal.>	3,677,000	Max	173,800	Min	44,000	Avg	118,613	Gpm	258											
Total Hrs.>	238.9	Max	11.5	Min	3	Avg	7.7													
Last Month.>	4,122,200	Max	194,600	Min	104,100	Avg	137,400	Gpm	269											
Last Year.>	3,892,700	Max	161,600	Min	93,500	Avg	125,600	Gpm	253											
Lbs.of Chlorine 612 Lbs of Fluoride 38 Gallons of salt brine 4,063																				
Chlorine.Mg/l	0.92	Fluoride.Mg/l	0.6	Hardness. Mg/l	91	Iron. Mg/l	0.01	Nitrate.Mg/l												
Well																				
Date	12/5/2022																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	30	14	16	110																
Well # 9	32	16	14	100																
Well # 10	24	8	14	100																
Well # 11	32	8	24	160																
<b>Water Meters</b>																				
	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio Read				Shut off For nonpayment															
	Repair																			
Fire Hydrants	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
Water Tower																				
Reservoir																				
Dist. System	12/27/22 - Water main break 9th and Sycamore 4" main																			
Wells	12/5/22 - Tested Wells 7-9-10-11 No issues																			
Other																				