

3/6/2023

Monthly Water Report

10:27 AM

Date	Feb-23																			
Water Plant																				
Total Gal.>	3,585,700	Max	243,800	Min	75,600	Avg	128,061	Gpm	259											
Total Hrs.>	233.4	Max	18.6	Min	5.8	Avg	8.3													
Last Month.>	3,899,600	Max	375,200	Min	60,600	Avg	125,794	Gpm	278											
Last Year.>	4,295,600	Max	279,500	Min	110,100	Avg	153,400	Gpm	251											
Lbs.of Chlorine		659	Lbs of Fluoride	51	Gallons of salt brine		2,483													
Chlorine.Mg/l	0.71	Fluoride.Mg/l	0.8	Hardness. Mg/l	88	Iron. Mg/l	0.02	Nitrate.Mg/l												
Well																				
Date	2/21/2023																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	26	14	12	110																
Well # 9	28	10	18	100																
Well # 10	24	10	14	110																
Well # 11	34	12	12	170																
Water Meters	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio Read				Shut off For nonpayment															
	Repair																			
Fire Hydrants	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
Water Tower																				
Reservoir																				
Dist. System	2/16/23 - Water Main break 1202 Sugar Grove 6" main Elite repaired for us. 2/24/23 - Water Main break in front of 2523 240th St. 6" main																			
Wells	2/21/23 - Tested Wells 7-9-10-11. Scheduled Well 11 to be cleaned.																			
Other																				