

2/10/2023

Monthly Water Report

1:50 PM

Date	Jan-23																			
Water Plant																				
Total Gal.>	3,899,600	Max	375,200	Min	60,600	Avg	125,794	Gpm	278											
Total Hrs.>	332.3	Max	107.1	Min	3.7	Avg	10.7193548													
Last Month.>	3,677,000	Max	173,800	Min	44,000	Avg	118,613	Gpm	258											
Last Year.>	2,023,700	Max	307,100	Min	0	Avg	65,300	Gpm	110											
Lbs.of Chlorine		492	Lbs of Fluoride	48	Gallons of salt brine	2,382														
Chlorine.Mg/l	1.05	Fluoride.Mg/l	0.7	Hardness. Mg/l	92	Iron. Mg/l	0.03	Nitrate.Mg/l												
Well																				
Date	1/5/2023																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	28	14	14	110																
Well # 9	28	12	14	100																
Well # 10	20	8	12	100																
Well # 11	32	8	24	160																
Water Meters	New Installs			Read In																
	Replace Meter			Read Out																
	Replace Radio Read			Shut off For nonpayment																
	Repair																			
Fire Hydrants	New Install			Flush Hyd			Repair Hyd													
Water Plant																				
Water Tower																				
Reservoir																				
Dist. System	1/4/23 - 702 Vine St Water main break 4"																			
Wells	1/5/23 Tested wells 7-9-10-11 no issues.																			
Other																				