

2/9/2024

Monthly Water Report

1:53 PM

Date	Jan-24																				
Water Plant																					
Total Gal.>	3,839,400	Max	177,800	Min	80,100	Avg	123,852	Gpm	256												
Total Hrs.>	252.8	Max	11.8	Min	4.6	Avg	8.15														
Last Month.>	3,573,500	Max	218,400	Min	53,800	Avg	115,274	Gpm	260												
Last Year.>	3,899,600	Max	375,200	Min	60,600	Avg	125,794	Gpm	278												
Lbs.of Chlorine	210	Lbs of Fluoride	67	Gallons of salt brine	2,144																
Chlorine.Mg/l	0.93	Fluoride.Mg/l	0.6	Hardness. Mg/l	74	Iron. Mg/l	0.01	Nitrate.Mg/l													
Well																					
Date	1/23/2024																				
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	
Well # 7	24	8	16	100																	
Well # 9	20	8	12	100																	
Well # 10	20	8	12	110																	
Well # 11	28	6	22	200																	
Water Meters																					
	New Installs				Read In																
	Replace Meter				Read Out																
	Replace Radio Read				Shut off For nonpayment																
	Repair																				
Fire Hydrants	New Install				Flush Hyd				Repair Hyd												
Water Plant																					
Water Tower																					
Reservoir																					
Dist. System																					
Wells	1/23/2024 - Tested Wells 7-9-10-11 no issues																				
Other																					