

8/3/2022

Monthly Water Report

12:02 PM

Date	22-Jul																			
Water Plant																				
Total Gal.>	4,895,400	Max	249,500	Min	83,700	Avg	157,900	Gpm	254											
Total Hrs.>	320.7	Max	13.4	Min	6.9	Avg	10.3													
Last Month.>	4,495,600	Max	210,300	Min	103,000	Avg	149,900	Gpm	257											
Last Year.>	4,656,400	Max	209,200	Min	104,800	Avg	150,200	Gpm	247											
Lbs.of Chlorine 737 Lbs of Fluoride 46 Gallons of salt brine 6,941																				
Chlorine.Mg/l 0.78 Fluoride.Mg/l 0.6 Hardness. Mg/l 78 Iron. Mg/l 0.01 Nitrate.Mg/l																				
Well																				
Date	7/6/2022																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	24	12	12	110																
Well # 9	26	12	14	110																
Well # 10	30	8	22	100																
Well # 11	28	12	16	220																
Water Meters																				
	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio Read				Shut off For nonpayment															
	Repair																			
Fire Hydrants																				
	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
7/21/22 - Backwashed Iron filters 1-2-3 no issues																				
Water Tower																				
Reservoir																				
Dist. System																				
7/25/22 Water main break. 6" main at 2525 240th St.																				
Wells																				
7/6/22 - Tested wells 7-9-10-11 no issues																				
Other																				