

8/3/2023

Monthly Water Report

9:19 AM

Date	Jul-23																							
Water Plant																								
Total Gal.>	4,663,300	Max	259,900	Min	34,200	Avg	150,429	Gpm	232															
Total Hrs.>	340.3	Max	21.4	Min	2.4	Avg	10.97741935																	
Last Month.>	4,702,200	Max	315,400	Min	70,000	Avg	156,700	Gpm	237															
Last Year.>	4,895,400	Max	249,500	Min	83,700	Avg	157,900	Gpm	254															
Lbs.of Chlorine 481 Lbs of Fluoride 48 Gallons of salt brine 3,702																								
Chlorine.Mg/l 0.93 Fluoride.Mg/l 0.7 Hardness. Mg/l 89 Iron. Mg/l 0.02 Nitrate.Mg/l																								
Well																								
Date	7/7/2023																							
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm				
Well # 7	20	6	14	120																				
Well # 9	22	10	12	100																				
Well # 10	20	8	12	120																				
Well # 11	28	6	22	230																				
Water Meters																								
	New Installs				Read In																			
	Replace Meter				Read Out																			
	Replace Radio Read				Shut off For nonpayment																			
	Repair																							
Fire Hydrants																								
	New Install				Flush Hyd				Repair Hyd															
Water Plant																								
Water Tower																								
Reservoir																								
Dist. System																								
Wells																								
Well 7 cleaned																								
Tested well 7-9-10-11 no issues																								
Other																								