

7/7/2023

## Monthly Water Report

2:50 PM

Date	Jun-23																			
<b>Water Plant</b>																				
Total Gal.>	4,702,200	Max	315,400	Min	70,000	Avg	156,700	Gpm	237											
Total Hrs.>	330.7	Max	19.9	Min	4.4	Avg	11.0													
Last Month.>	4,593,700	Max	258,100	Min	59,900	Avg	148,184	Gpm	237											
Last Year.>	4,495,600	Max	210,300	Min	103,000	Avg	149,900	Gpm	257											
Lbs.of Chlorine	342	Lbs of Fluoride	49	Gallons of salt brine	4,052															
Chlorine.Mg/l	0.64	Fluoride.Mg/l	0.7	Hardness. Mg/l	91	Iron. Mg/l	0.03	Nitrate.Mg/l												
Well																				
Date	6/7/2023																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	24	6	18	60																
Well # 9	24	12	12	100																
Well # 10	26	10	16	120																
Well # 11	32	8	24	240																
<b>Water Meters</b>																				
	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio				Shut off For nonpayment															
	Read																			
	Repair																			
Fire Hydrants	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
Water Tower																				
Reservoir																				
Dist. System																				
Wells	6/7/2023 - Tested wells 7-9-10-11. Called Northway to clean Well 7 due to low production.																			
Other																				