

4/4/2023

Monthly Water Report

1:52 PM

Date	Mar-23																			
Water Plant																				
Total Gal.>	3,555,900	Max	217,500	Min	32,400	Avg	114,706	Gpm	240											
Total Hrs.>	260.4	Max	23.2	Min	2.6	Avg	8.4													
Last Month.>	3,585,700	Max	243,800	Min	75,600	Avg	128,061	Gpm	259											
Last Year.>	4,228,200	Max	258,600	Min	47,100	Avg	136,400	Gpm	263											
Lbs.of Chlorine	557	Lbs of Fluoride	49	Gallons of salt brine	2,365															
Chlorine.Mg/l	1.1	Fluoride.Mg/l	0.9	Hardness. Mg/l	89	Iron. Mg/l	0.02	Nitrate.Mg/l												
Well																				
Date	3/22/2023																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	24	14	10	110																
Well # 9	26	12	14	100																
Well # 10	24	10	14	120																
Well # 11	33	16	17	170																
Water Meters																				
	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio				Shut off For nonpayment															
	Read																			
	Repair																			
Fire Hydrants																				
	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
Water Tower																				
Reservoir																				
3/19/2023 - Reservoir booster pumps failed. Had to bypass the reservoir.																				
3/26/23 - Reservoir new pump stopped working																				
Dist. System																				
3/20/23 - Watermain break at 15th & Vine. 4" main																				
Wells																				
3/22/23 - Tested wells 7-9-10-11. Well #11 scheduled to be cleaned.																				
Other																				