

4/19/2024

Monthly Water Report

10:55 AM

Date	Mar-24																			
Water Plant																				
Total Gal.>	3,695,000	Max	150,300	Min	67,600	Avg	119,194	Gpm	241											
Total Hrs.>	256.2	Max	10.5	Min	4.7	Avg	8.26451613													
Last Month.>	3,579,400	Max	249,500	Min	78,500	Avg	123,428	Gpm	254											
Last Year.>	3,555,900	Max	217,500	Min	32,400	Avg	114,706	Gpm	240											
Lbs.of Chlorine	130	Lbs of Fluoride	97	Gallons of salt brine	7,045															
Chlorine.Mg/l	0.73	Fluoride.Mg/l	0.6	Hardness. Mg/l	88	Iron. Mg/l	0	Nitrate.Mg/l												
Well																				
Date	3/7/2024																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	18	8	10	120																
Well # 9	20	8	12	100																
Well # 10	20	10	10	120																
Well # 11	32	6	26	200																
Water Meters	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio				Shut off For nonpayment															
	Read																			
	Repair																			
Fire Hydrants	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
Water Tower																				
Reservoir																				
Dist. System																				
Wells	3/7/2024 - Tested wells 7-9-10-11 no issues.																			
Other																				