

6/27/2023

Monthly Water Report

11:57 AM

Date	May-23																			
Water Plant																				
Total Gal.>	4,593,700	Max	258,100	Min	59,900	Avg	148,184	Gpm	237											
Total Hrs.>	329	Max	18.6	Min	4.5	Avg	10.6													
Last Month.>	4,174,700	Max	217,500	Min	32,400	Avg	114,706	Gpm	240											
Last Year.>	4,772,400	Max	212,400	Min	72,000	Avg	141,000	Gpm	259											
Lbs.of Chlorine 298 Lbs of Fluoride 58 Gallons of salt brine 4,101																				
Chlorine.Mg/l 0.71 Fluoride.Mg/l 0.7 Hardness. Mg/l 88 Iron. Mg/l 0.02 Nitrate.Mg/l																				
Well																				
Date	5/4/2023																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	28	14	14	120																
Well # 9	24	10	14	100																
Well # 10	24	10	14	120																
Well # 11	32	12	20	250																
Water Meters																				
	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio Read				Shut off For nonpayment															
	Repair																			
Fire Hydrants																				
	New Install				Flush Hyd				all				Repair Hyd							
Water Plant																				
Water Tower																				
Reservoir																				
Dist. System																				
5/26/23 - Water main break 12th and Linden 12" main																				
5/30/23 - Highway 44 main replacement went on line.																				
All fire hydrants were flushed throughout the month of May.																				
Wells																				
5/4/23 - Tested wells 7-9-10-11 no issues																				
Other																				