

12/7/2022

Monthly Water Report

8:05 AM

Date	Nov-22																				
Water Plant																					
Total Gal.>	4,122,200	Max	194,600	Min	104,100	Avg	137,400	Gpm	269												
Total Hrs.>	270.2	Max	13.2	Min	3.9	Avg	9.0														
Last Month.>	4,103,900	Max	197,600	Min	89,300	Avg	132,400	Gpm	259												
Last Year.>	3,835,700	Max	163,500	Min	102,300	Avg	127,900	Gpm	255												
Lbs.of Chlorine 655 Lbs of Fluoride 50 Gallons of salt brine 2,937																					
Chlorine.Mg/l	0.95	Fluoride.Mg/l	0.6	Hardness. Mg/l	94	Iron. Mg/l	0.01	Nitrate.Mg/l													
Well																					
Date	11/9/2022																				
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	
Well # 7	28	20	8	110																	
Well # 9	36	22	14	100																	
Well # 10	24	6	18	100																	
Well # 11	28	10	18	220																	
Water Meters																					
	New Installs				Read In																
	Replace Meter				Read Out																
	Replace Radio				Shut off For																
	Read				nonpayment																
	Repair																				
Fire Hydrants																					
	New Install				Flush Hyd				Repair Hyd												
Water Plant																					
Water Tower																					
Reservoir																					
Dist. System																					
Wells	11/9/22 - Tested Wells 7-9-10-11 no issues																				
Other																					