

12/8/2023

Monthly Water Report

9:32 AM

Date	Nov-23											
Water Plant												
Total Gal.>	3,607,000	Max	253,600	Min	70,500	Avg	120,233	Gpm	280			
Total Hrs.>	279.6	Max	38.5	Min	1.6	Avg	9.32					
Last Month.>	4,103,900	Max	197,600	Min	89,300	Avg	132,400	Gpm	259			
Last Year.>	4,122,200	Max	194,600	Min	104,100	Avg	137,400	Gpm	269			
Lbs.of Chlorine 252 Lbs of Fluoride 43 Gallons of salt brine 4,473												
Chlorine.Mg/l	0.73	Fluoride.Mg/l	0.5	Hardness. Mg/l	89	Iron. Mg/l	0.02	Nitrate.Mg/l				
Well												
Date	11/16/2023											
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	24	12	12	110								
Well # 9	24	8	16	100								
Well # 10	20	8	12	110								
Well # 11	30	4	26	230								
Water Meters												
	New Installs				Read In							
	Replace Meter				Read Out							
	Replace Radio Read				Shut off For nonpayment							
	Repair											
Fire Hydrants	New Install				Flush Hyd				Repair Hyd			
Water Plant	Back washed filters 1-2-3 no issues.											
Water Tower												
Reservoir												
Dist. System	11/9/2023 - Water main break 1706 Vine St 4" main											
Wells	11/16/2023 - Tested Wells 7-9-10-11 no issues.											
Other												