

11/3/2022

Monthly Water Report

8:49 AM

Date	Oct-22																			
Water Plant																				
Total Gal.>	4,103,900	Max	197,600	Min	89,300	Avg	132,400	Gpm	259											
Total Hrs.>	357	Max	106.7	Min	5.8	Avg	11.516129													
Last Month.>	4,153,400	Max	177,700	Min	86,600	Avg	138,400	Gpm	268											
Last Year.>	4,803,500	Max	292,500	Min	61,700	Avg	155,000	Gpm	253											
Lbs.of Chlorine 680 Lbs of Fluoride 61 Gallons of salt brine 3,748																				
Chlorine.Mg/l 0.7 Fluoride.Mg/l 0.6 Hardness. Mg/l 90 Iron. Mg/l 0.01 Nitrate.Mg/l																				
Well																				
Date	10/20/2022																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	28	22	6	110																
Well # 9	34	22	12	100																
Well # 10	24	6	18	100																
Well # 11	28	10	18	230																
Water Meters																				
	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio				Shut off For nonpayment															
	Read																			
	Repair																			
Fire Hydrants																				
	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
Water Tower																				
Reservoir																				
Dist. System 10/17/22 - Water main break 1500 block of Sycamore, 4" main.																				
Wells 10/20/21 - Tested wells 7-9-10-11 no issues.																				
Other																				