

11/7/2023

Monthly Water Report

8:57 AM

Date	Oct-23																			
Water Plant																				
Total Gal.>	3,610,300	Max	266,400	Min	9,200	Avg	116,461	Gpm	231											
Total Hrs.>	453.2	Max	206.9	Min	0.6	Avg	14.6													
Last Month.>	3,923,200	Max	184,500	Min	90,100	Avg	130,773	Gpm	245											
Last Year.>	4,103,900	Max	197,600	Min	89,300	Avg	132,400	Gpm	259											
Lbs.of Chlorine	315	Lbs of Fluoride	63	Gallons of salt brine	4,651															
Chlorine.Mg/l	0.58	Fluoride.Mg/l	0.6	Hardness. Mg/l	84	Iron. Mg/l	0.02	Nitrate.Mg/l												
Well																				
Date	10/23/2023																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	24	10	14	110																
Well # 9	24	8	16	100																
Well # 10	20	8	12	110																
Well # 11	24	4	20	220																
Water Meters	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio Read				Shut off For nonpayment															
	Repair																			
Fire Hydrants	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
Water Tower																				
Reservoir	10/19/2023 - Installed new VFD for pump 1.																			
Dist. System																				
Wells	10/23/2023 - Tested Wells 7-9-10-11 no issues																			
Other																				