

10/6/2023

Monthly Water Report

1:16 PM

Date	Sep-23																			
Water Plant																				
Total Gal.>	3,923,200	Max	184,500	Min	90,100	Avg	130,773	Gpm	245											
Total Hrs.>	269.6	Max	12.7	Min	5	Avg	9.0													
Last Month.>	4,541,300	Max	215,800	Min	90,500	Avg	146,494	Gpm	249											
Last Year.>	4,153,400	Max	177,700	Min	86,600	Avg	138,400	Gpm	268											
Lbs.of Chlorine	256	Lbs of Fluoride	55	Gallons of salt brine		5,140														
Chlorine.Mg/l	0.65	Fluoride.Mg/l	0.6	Hardness. Mg/l	97	Iron. Mg/l	0.03	Nitrate.Mg/l												
Well																				
Date	9/12/2023																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	24	8	16	115																
Well # 9	24	10	14	100																
Well # 10	22	8	14	120																
Well # 11	28	4	24	220																
Water Meters																				
	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio				Shut off For nonpayment															
	Read																			
	Repair																			
Fire Hydrants																				
	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
Water Tower																				
Reservoir																				
Dist. System																				
Wells																				
9/12/2023 - Tested Wells 7-9-10-11 no issues.																				
Other																				