

12/6/2021

Monthly Water Report

1:57 PM

Date	Nov-21																			
Water Plant																				
Total Gal.>	3,835,700	Max	163,500	Min	102,300	Avg	127,900	Gpm	255											
Total Hrs.>	252.2	Max	10.7	Min	6.5	Avg	8.41													
Last Month.>	4,803,500	Max	292,500	Min	61,700	Avg	155,000	Gpm	253											
Last Year.>	4,069,900	Max	181,200	Min	108,600	Avg	135,700	Gpm	257											
Lbs.of Chlorine 566 Lbs of Fluoride 38 Gallons of salt brine 2,762																				
Chlorine.Mg/l	0.73	Fluoride.Mg/l	0.5	Hardness. Mg/l	124	Iron. Mg/l	0.1	Nitrate.Mg/l												
Well																				
Date	11/4/2021																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	36	20	16	110																
Well # 9	36	26	10	100																
Well # 10	24	12	12	100																
Well # 11	32	26	8	240																
Water Meters																				
	New Installs			Read In																
	Replace Meter			Read Out																
	Replace Radio			Shut off For																
	Read			nonpayment																
	Repair																			
Fire Hydrants																				
	New Install			Flush Hyd				Repair Hyd												
Water Plant																				
	Installed new Iron Filters and media																			
Water Tower																				
Reservoir																				
Dist. System																				
Wells																				
	11/4/2021 - Tested wells 7-9-10-11 with no issues.																			
Other																				