

10/7/2022

Monthly Water Report

12:43 PM

Date	Sep-22																				
Water Plant																					
Total Gal.>	4,153,400	Max	177,700	Min	86,600	Avg	138,400	Gpm	268												
Total Hrs.>	266.7	Max	12.3	Min	5.5	Avg	8.89														
Last Month.>	4,881,800	Max	255,000	Min	52,300	Avg	157,500	Gpm	262												
Last Year.>	4,841,600	Max	220,800	Min	124,100	Avg	161,400	Gpm	247												
Lbs.of Chlorine 594 Lbs of Fluoride 62 Gallons of salt brine 4,788																					
Chlorine.Mg/l	0.74	Fluoride.Mg/l	0.6	Hardness. Mg/l	91	Iron. Mg/l	0.01	Nitrate.Mg/l													
Well																					
Date	9/8/2022																				
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	
Well # 7	30	22	8	120																	
Well # 9	34	24	10	100																	
Well # 10	22	8	14	90																	
Well # 11	26	8	18	180																	
Water Meters		New Installs			Read In																
		Replace Meter			Read Out																
		Replace Radio Read			Shut off For nonpayment																
		Repair																			
Fire Hydrants	New Install			Flush Hyd			Repair Hyd														
Water Plant	9/29/22 - Installed new chlorine pump																				
Water Tower																					
Reservoir																					
Dist. System	9/29/22 - Water main break just east of 2415 240th St. 6" main.																				
Wells	9/8/22 - Tested wells 7-9-10-11 no issues.																				
Other																					