

Monthly Water Report

Date	Feb-19																			
	Water Plant																			
Total Gal.>	4,043,500	Max	238,100	Min	95,400	Avg	144,400	Gpm	257											
Total Hrs.>	261.4	Max	14.4	Min	5.7	Avg	9.33571429													
Last Month.>	4,385,500	Max	435,500	Min	102,900	Avg	141,500	Gpm	246											
Last Year.>	4,251,800	Max	229,400	Min	86,900	Avg	155,400	Gpm	253											
Lbs.of Chlorine	435	Lbs of Fluoride	20	Gallons of salt brine	1,069															
Chlorine.Mg/l	0.8	Fluoride.Mg/l	0.6	Hardness. Mg/l	114	Iron. Mg/l	0.01	Nitrate.Mg/l												
	Well																			
Date	2/26/2019																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	34	22	12	160																
Well # 8	34	26	8	110																
Well # 9	36	30	6	170																
Well # 10	25	12	13	130																
Test Well																				
Water Meters	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio				Shut off For nonpayment															
	Read																			
	Repair																			
Fire Hydrants	New Install				Flush Hyd				Repair Hyd											
Water Plant	2/13/2019 - Backwashed filters 1-2-3.																			
Water Tower																				
Reservoir																				
Dist. System	2/11/2019 - 4" Water main repair in front of 708 Vine 2/16/2019 - 4" Water main repair at Hatton and Sycamore																			
Wells	2/26/2019 - Tested wells 7-8-9-10 no issues																			
Other																				