

Monthly Water Report

Date	Jan-19																			
Water Plant																				
Total Gal.>	4,385,500	Max	435,500	Min	102,900	Avg	141,500	Gpm	246											
Total Hrs.>	589.2	Max	308.7	Min	6.5	Avg	19.0064516													
Last Month.>	4,263,800	Max	453,500	Min	47,800	Avg	137,500	Gpm	265											
Last Year.>	4,895,000	Max	345,500	Min	44,200	Avg	157,900	Gpm	254											
Lbs.of Chlorine 538 Lbs of Fluoride 29 Gallons of salt brine 2,529																				
Chlorine.Mg/l	0.78	Fluoride.Mg/l	0.6	Hardness. Mg/l	120	Iron. Mg/l	0.01	Nitrate.Mg/l												
Well																				
Date	1/16/2019																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	34	22	12	140																
Well # 8	36	22	14	100																
Well # 9	34	26	8	140																
Well # 10	30	14	16	120																
Test Well																				
Water Meters																				
	New Installs			Read In																
	Replace Meter			Read Out																
	Replace Radio			Shut off For																
	Read			nonpayment																
	Repair																			
Fire Hydrants	New Install			Flush Hyd			Repair Hyd													
Water Plant																				
Water Tower																				
Reservoir																				
Dist. System	1/9/2019 - 10th & Sycamore 4" water main break 1/19/2019 - Hatton & Sycamore 4" water main break																			
Wells	1/10/2019 - Northway Well cleaned well 9 1/16/2019 - Tested Wells 7-8-9-10 no issues																			
Other	1/17/2019 installed new radios at wells, water plant and reservoir.																			