

Monthly Water Report

Date	Mar-19														
Water Plant															
Total Gal.>	5,068,500	Max	223,200	Min	114,800	Avg	163,500	Gpm	259						
Total Hrs.>	327.1	Max	13.6	Min	7.6	Avg	10.5								
Last Month.>	4,043,500	Max	238,100	Min	95,400	Avg	144,400	Gpm	257						
Last Year.>	4,126,800	Max	159,600	Min	102,600	Avg	133,100	Gpm	265						
Lbs.of Chlorine	545	Lbs of Fluoride	27	Gallons of salt brine		2,750									
Chlorine.Mg/l	0.73	Fluoride.Mg/l	0.6	Hardness. Mg/l		103	Iron. Mg/l	0.01	Nitrate.Mg/l						
Well															
Date	3/27/2019														
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD
Well # 7	42	24	18	170											
Well # 8	40	28	12	100											
Well # 9	37	30	7	180											
Well # 10	25	8	17	120											
Test Well															
Water Meters	New Installs			Read In											
	Replace Meter			Read Out											
	Replace Radio			Shut off For nonpayment											
	Read														
	Repair														
Fire Hydrants	New Install			Flush Hyd			Repair Hyd								
Water Plant	3/6/2019 - Backwashed filters 1-2-3 no issues.														
Water Tower	3/25/2019 - 3/28/2019 - Raised tower level to 27 feet for summer level.														
Reservoir															
Dist. System															
Wells	3/27/2019 - Tested wells 7-8-9-10														
Other															