

Monthly Water Report

Date	Apr-19											
Water Plant												
Total Gal.>	5,405,200	Max	227,300	Min	136,700	Avg	180,200	Gpm	257			
Total Hrs.>	354.8	Max	15.6	Min	8.3	Avg	11.8					
Last Month.>	5,068,500	Max	223,200	Min	114,800	Avg	163,500	Gpm	259			
Last Year.>	4,190,900	Max	236,300	Min	43,900	Avg	139,700	Gpm	259			
Lbs.of Chlorine 528 Lbs of Fluoride 30 Gallons of salt brine 4,093												
Chlorine.Mg/l	0.72	Fluoride.Mg/l	0.5	Hardness. Mg/l	104	Iron. Mg/l	0.01	Nitrate.Mg/l				
Well												
Date	4/29/2019											
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	35	20	15	160								
Well # 8	35	28	7	90								
Well # 9	32	26	6	200								
Well # 10	30	10	20	120								
Test Well												
Water Meters												
	New Installs			Read In								
	Replace Meter			Read Out								
	Replace Radio			Shut off For								
	Read			nonpayment								
	Repair											
Fire Hydrants												
	New Install			Flush Hyd			Repair Hyd					
Water Plant												
	4/8/19 - Backwashed filters 1-2-3											
	4/16/19 - DMC Welding repair 4 pin holes in filter 1.											
Water Tower												
Reservoir												
Dist. System												
Wells												
	4/29/19 - Tested Wells 7-8-9-10 with no issues											
Other												