

5/5/2021

Monthly Water Report

10:48 AM

Date	Apr-21																			
Water Plant																				
Total Gal.>	4,180,600	Max	194,800	Min	102,500	Avg	139,400	Gpm	257											
Total Hrs.>	275.5	Max	13.4	Min	4.9	Avg	9.2													
Last Month.>	3,962,300	Max	213,800	Min	74,500	Avg	127,800	Gpm	261											
Last Year.>	4,222,900	Max	222,200	Min	76,400	Avg	140,800	Gpm	232											
Lbs.of Chlorine	544	Lbs of Fluoride	38	Gallons of salt brine		6,887														
Chlorine.Mg/l	0.84	Fluoride.Mg/l	0.6	Hardness. Mg/l		90	Iron. Mg/l	0.01	Nitrate.Mg/l											
Well																				
Date	4/16/2021																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	30	12	18	120																
Well # 9	26	24	2	60																
Well # 10	24	10	14	100																
Well # 11	30	12	18	260																
Water Meters		New Installs			Read In															
		Replace Meter			Read Out															
		Replace Radio			Shut off For nonpayment															
		Read																		
		Repair																		
Fire Hydrants		New Install			Flush Hyd			Repair Hyd												
Water Plant		4/6/21 - Backwashed Iron filters 1-2-3.																		
Water Tower																				
Reservoir																				
Dist. System																				
Wells		4/16/21 - Tested wells 7-9-10-11. Called Northway to clean well 9 low GPM. 4/23/21 - Northway came to clean Well 9 and found pump and motor were bad and not working.																		
Other																				