

Monthly Water Report

Date	Dec-20																				
Water Plant																					
Total Gal.>	4,636,900	Max	256,000	Min	85,700	Avg	150	Gpm	245												
Total Hrs.>	305.2	Max	17.1	Min	5.2	Avg	9.8														
Last Month.>	4,069,900	Max	181,200	Min	108,600	Avg	135,700	Gpm	257												
Last Year.>	3,689,600	Max	149,900	Min	83,100	Avg	119,000	Gpm	239												
Lbs.of Chlorine 535 Lbs of Fluoride 41 Gallons of salt brine 3,678																					
Chlorine.Mg/l	0.72	Fluoride.Mg/l	0.6	Hardness. Mg/l	104	Iron. Mg/l	0.01	Nitrate.Mg/l													
Well																					
Date	12/17/2020																				
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	
Well # 7	32	20	12	120																	
Well # 9	36	24	12	80																	
Well # 10	24	10	14	110																	
Well # 11	30	18	12	265																	
Test Well																					
Water Meters																					
	New Installs				Read In																
	Replace Meter				Read Out																
	Replace Radio Read				Shut off For nonpayment																
	Repair																				
Fire Hydrants																					
	New Install				Flush Hyd				Repair Hyd												
Water Plant																					
12/9/2020 - Backashed iron filters.																					
12/16/2020 - Installed new raw water meter at water plant																					
12/23/2020 - Installed in brine pump																					
Water Tower																					
Reservoir																					
Electric Pump installed booster pump																					
Dist. System																					
12/12/2020 - Main break 13th and Ash.																					
Wells																					
Tested Wells 7-9-10-11 no issues																					
Other																					