

3/4/2021

Monthly Water Report

2:15 PM

Date	Feb-21																			
Water Plant																				
Total Gal.>	5,110,900	Max	272,600	Min	141,300	Avg	182,500	Gpm	241											
Total Hrs.>	355.5	Max	21.9	Min	8.6	Avg	12.7													
Last Month.>	4,865,500	Max	246,300	Min	52,200	Avg	157,000	Gpm	251											
Last Year.>	3,790,500	Max	169,000	Min	93,200	Avg	130,700	Gpm	263											
Lbs.of Chlorine 717 Lbs of Fluoride 43 Gallons of salt brine 7,903																				
Chlorine.Mg/l 0.85 Fluoride.Mg/l 0.7 Hardness. Mg/l 93 Iron. Mg/l 0.02 Nitrate.Mg/l																				
Well																				
Date	2/10/2021																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	32	22	10	130																
Well # 9	32	28	4	100																
Well # 10	24	10	14	70																
Well # 11	28	12	16	250																
Water Meters																				
	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio				Shut off For nonpayment															
	Read																			
	Repair																			
Fire Hydrants																				
	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
	2/3/21- Backwashed iron filters																			
Water Tower																				
Reservoir																				
Dist. System																				
	2/14/21 - Water main break 902 Sycamore 4" main																			
	2/17/21 - 12th and Vine 4" water main break																			
Wells																				
	2/10/21 - Checked wells 7-9-10-11.																			
Other																				