

# Monthly Water Report

Date	Jan-20											
Water Plant												
Total Gal.>	4,095,700	Max	273,200	Min	30,800	Avg	132,100	Gpm	264			
Total Hrs.>	271.1	Max	19.6	Min	1.7	Avg	8.7					
Last Month.>	3,689,600	Max	149,900	Min	83,100	Avg	119,000	Gpm	239			
Last Year.>	4,385,500	Max	435,500	Min	102,900	Avg	141,500	Gpm	246			
Lbs.of Chlorine 461 Lbs of Fluoride 35 Gallons of salt brine 6,109												
Chlorine.Mg/l 0.88 Fluoride.Mg/l 0.6 Hardness. Mg/l 103 Iron. Mg/l 0.01 Nitrate.Mg/l												
Well												
Date	1/24/2020											
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	34	18	16	150								
Well # 8												
Well # 9	30	26	4	190								
Well # 10	30	12	8	120								
Test Well												
Water Meters												
	New Installs			Read In								
	Replace Meter			Read Out								
	Replace Radio			Shut off For								
	Repair			nonpayment								
Fire Hydrants												
	New Install			Flush Hyd			Repair Hyd					
Water Plant												
Water Tower												
Reservoir												
Dist. System												
1/16/20 - Water main break 300 block of 13th St. 4" main.												
Wells												
Tested Wells 7-9-10 no issues												
Other												