

2/2/2021

## Monthly Water Report

11:22 AM

Date	Jan-21																			
Water Plant																				
Total Gal.>	4,865,500	Max	246,300	Min	52,200	Avg	157,000	Gpm	251											
Total Hrs.>	322.1	Max	15.1	Min	3.9	Avg	10.4													
Last Month.>	4,636,900	Max	256,000	Min	85,700	Avg	150	Gpm	245											
Last Year.>	4,095,700	Max	273,200	Min	30,800	Avg	132,100	Gpm	264											
Lbs.of Chlorine 658 Lbs of Fluoride 38 Gallons of salt brine 7,425																				
Chlorine.Mg/l 0.77 Fluoride.Mg/l 0.6 Hardness. Mg/l 100 Iron. Mg/l 0.01 Nitrate.Mg/l																				
Well																				
Date	1/20/2021																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	34	22	12	130																
Well # 9	32	26	6	100																
Well # 10	24	8	16	80																
Well # 11	28	10	18	260																
Water Meters																				
	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio Read				Shut off For nonpayment															
	Repair																			
Fire Hydrants																				
	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
	1/6/21 - Backwashed filter 1-2-3 no issues.																			
Water Tower																				
Reservoir																				
Dist. System																				
	1/28/21 - 4" Water main break. Just East of 14th & Sycamore																			
	1/31/21 - 4" Water main break. Just West of 13th & Sycamore																			
Wells																				
	1/20/21 - Checked Well 7-9-10-11. Well 10 GPM is down called to have it cleaned.																			
Other																				