

Monthly Water Report

Date	Jun-19																			
Water Plant																				
Total Gal.>	6,501,700	Max	303,100	Min	165,300	Avg	216,700	Gpm	252											
Total Hrs.>	432.8	Max	22.7	Min	11.3	Avg	14.4													
Last Month.>	6,245,100	Max	258,300	Min	123,000	Avg	201,500	Gpm	251											
Last Year.>	4,121,200	Max	245,300	Min	86,400	Avg	137,400	Gpm	254											
Lbs.of Chlorine 677 Lbs of Fluoride 29 Gallons of salt brine 1,963																				
Chlorine.Mg/l 0.65 Fluoride.Mg/l 0.5 Hardness. Mg/l 115 Iron. Mg/l 0.01 Nitrate.Mg/l																				
Well																				
Date	6/27/2019																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	42	22	20	150																
Well # 8	36	30	6	80																
Well # 9	35	28	7	220																
Well # 10	28	8	20	110																
Test Well																				
Water Meters																				
	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio Read				Shut off For nonpayment															
	Repair																			
Fire Hydrants																				
	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
Water Tower																				
6/12/2019 - Cleaned inside of water tower																				
6/27/2019 - Cleaned outside of water tower																				
Reservoir																				
Dist. System																				
6/21/2019 - Water main break west of 2553 240th.																				
Wells																				
6/27/2019 - Tested wells 7-8-9-10. Well 8 pumping is down. Called Northway Well to clean.																				
Other																				