

7/9/2020

Monthly Water Report

9:34 AM

Date	Jun-20																			
Water Plant																				
Total Gal.>	4,833,500	Max	309,400	Min	83,400	Avg	161,100	Gpm	231											
Total Hrs.>	350.3	Max	16.5	Min	6.6	Avg	11.7													
Last Month.>	5,334,700	Max	270,900	Min	108,500	Avg	172,100	Gpm	257											
Last Year.>	6,501,700	Max	303,100	Min	165,300	Avg	216,700	Gpm	252											
Lbs.of Chlorine 764 Lbs of Fluoride 59 Gallons of salt brine 5,003																				
Chlorine.Mg/l 0.77 Fluoride.Mg/l 0.4 Hardness. Mg/l 114 Iron. Mg/l 0.02 Nitrate.Mg/l																				
Well																				
Date	6/26/2020																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	35	28	7	80																
Well # 8																				
Well # 9	40	32	8	120																
Well # 10	24	8	16	130																
Test Well																				
Water Meters																				
	Now Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio				Shut off For															
	Read				nonpayment															
	Repair																			
Fire Hydrants																				
	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
	6/22/2020 - Backwashed filters 1-2-3 no issues.																			
Water Tower																				
Reservoir																				
Dist. System																				
Wells																				
	6/26/2020 - Tested wells 7-9-10. Found Well 9 not running.																			
	6/26/2020 - Northway Well came to look at Well 9. Found Wasp nest on Contactor.																			
	6/29/2020 Northway Well cleaned Well 7 due to low production.																			
Other																				