

7/8/2021

Monthly Water Report

3:50 PM

Date	Jun-21																	
Water Plant																		
Total Gal.>	5,943,900	Max	373,500	Min	104,400	Avg	198,100	Gpm	254									
Total Hrs.>	391.9	Max	22.6	Min	6.4	Avg	13.1											
Last Month.>	4,799,900	Max	228,500	Min	104,000	Avg	154,800	Gpm	251									
Last Year.>	4,833,500	Max	309,400	Min	83,400	Avg	161,100	Gpm	231									
Lbs. of Chlorine 788 Lbs of Fluoride 52 Gallons of salt brine 8,011																		
Chlorine.Mg/l	0.81	Fluoride.Mg/l	0.5	Hardness. Mg/l	90	Iron. Mg/l	0.01	Nitrate.Mg/l										
Well																		
Date	6/17/2021																	
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm		
Well # 7	28	14	14	120														
Well # 9	28	22	6	110														
Well # 10	24	10	14	120														
Well # 11	28	12	16	250														
Water Meters																		
	New Installs			Read In														
	Replace Meter			Read Out														
	Replace Radio			Shut off For														
	Read			nonpayment														
	Repair																	
Fire Hydrants																		
	New Install			Flush Hyd			Repair Hyd											
Water Plant																		
Water Tower																		
	6/9/2021 - Maguire Iron Inc. cleaned water tower.																	
Reservoir																		
	Backup generator automatic transfer switch installed.																	
Dist. System																		
	Flushed Hydrants throughout the month																	
	6/30/2021 - Water main break at 105 10th street. 6" main																	
Wells																		
	6/17/2021 - Tested wells 7-9-10-11 no issues																	
Other																		