

Monthly Water Report

Date	20-Mar											
Water Plant												
Total Gal.>	3,822,200	Max	214,800	Min	60,400	Avg	123,300	Gpm	240			
Total Hrs.>	270.8	Max	18	Min	3.3	Avg	8.7					
Last Month.>	3,790,500	Max	169,000	Min	93,200	Avg	130,700	Gpm	263			
Last Year.>	5,068,500	Max	223,200	Min	114,800	Avg	163,500	Gpm	259			
Lbs. of Chlorine 519 Lbs of Fluoride 40 Gallons of salt brine 5,985												
Chlorine.Mg/l	0.76	Fluoride.Mg/l	0.6	Hardness. Mg/l	112	Iron. Mg/l	0.01	Nitrate.Mg/l				
Well												
Date	3/12/2020											
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	32	22	10	130								
Well # 8												
Well # 9	30	26	6	150								
Well # 10	20	8	12	130								
Test Well												
Water Meters												
	New Installs			Read In								
	Replace Meter			Read Out								
	Replace Radio			Shut off For								
	Read			nonpayment								
	Repair											
Fire Hydrants												
	New Install			Flush Hyd			Repair Hyd					
Water Plant												
	3/1 - Replaced chlorine feed pump											
	3/3-3/4 - Water Surplus opened softners and filter to inspect and test media.											
	3/26 - Backwashed Filters 1-2-3											
Water Tower												
	3/4 - Power failure caused by battery backup failed.											
Reservoir												
	3-28 - Cleaned and Inspected Reservoir											
Dist. System												
Wells												
	3/12 - Tested wells 7-9-10 no issues											
Other												