

4/7/2021

Monthly Water Report

9:15 AM

Date	Mar-21											
Water Plant												
Total Gal.>	3,962,300	Max	213,800	Min	74,500	Avg	127,800	Gpm	261			
Total Hrs.>	264.7	Max	13.8	Min	4.4	Avg	8.5					
Last Month.>	5,110,900	Max	272,600	Min	141,300	Avg	182,500	Gpm	241			
Last Year.>	3,822,200	Max	214,800	Min	60,400	Avg	123,300	Gpm	240			
Lbs.of Chlorine 496 Lbs of Fluoride 30 Gallons of salt brine 5,702												
Chlorine.Mg/l	0.79	Fluoride.Mg/l	0.7	Hardness.Mg/l	91	Iron.Mg/l	0.01	Nitrate.Mg/l				
Well												
Date	3/26/2021											
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	30	16	14	120								
Well # 9	28	24	4	90								
Well # 10	25	8	17	100								
Well # 11	32	12	20	260								
Water Meters												
	New Installs			Read In								
	Replace Meter			Read Out								
	Replace Radio			Shut off For nonpayment								
	Repair											
Fire Hydrants												
	New Install			Flush Hyd			Repair Hyd					
Water Plant												
	3/3/21 - Backwashed Iron filters 1-2-3											
Water Tower												
Reservoir												
Dist. System												
Wells												
	3/18/21 - Northway Well cleaned Well 10											
	3/26/21 - Tested wells 7-9-10-11 no issues											
	Generator was set and wired for wells 9 and 10. Waiting for 3E to come do start up and training.											
Other												