

Monthly Water Report

Date	May-19																			
Water Plant																				
Total Gal.>	6,245,100	Max	258,300	Min	123,000	Avg	201,500	Gpm	251											
Total Hrs.>	417	Max	18.6	Min	7.4	Avg	13.4516129													
Last Month.>	5,405,200	Max	227,300	Min	136,700	Avg	180,200	Gpm	257											
Last Year.>	5,004,300	Max	297,200	Min	45,500	Avg	161,400	Gpm	255											
Lbs.of Chlorine 691 Lbs of Fluoride 34 Gallons of salt brine 3,179																				
Chlorine.Mg/l 0.76 Fluoride.Mg/l 0.5 Hardness. Mg/l 101 Iron. Mg/l 0 Nitrate.Mg/l																				
Well																				
Date	5/17/2019																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	38	24	14	170																
Well # 8	35	26	9	100																
Well # 9	32	24	8	190																
Well # 10	32	10	22	120																
Test Well																				
Water Meters																				
	New Installs			Read In																
	Replace Meter			Read Out																
	Replace Radio			Shut off For nonpayment																
	Read																			
	Repair																			
Fire Hydrants																				
	New Install			Flush Hyd				Repair Hyd												
Water Plant																				
	5/9/19 - Backwashed Filters 1-2-3																			
Water Tower																				
Reservoir																				
Dist. System																				
Wells																				
	5/17/19 - Tested wells 7-8-9-10 no issues.																			
Other																				