

# Monthly Water Report

Date	May-20																			
	<b>Water Plant</b>																			
Total Gal.>	5,334,700	Max	270,900	Min	108	Avg	172,100	Gpm	0.2											
Total Hrs.>	398.4	Max	21.1	Min	7.8	Avg	12.9													
Last Month.>	4,222,900	Max	222,200	Min	76,400	Avg	140,800	Gpm	232											
Last Year.>	6,245,100	Max	258,300	Min	123,000	Avg	201,500	Gpm	251											
Lbs.of Chlorine	750	Lbs of Fluoride	30	Gallons of salt brine	6,641															
Chlorine.Mg/l	0.79	Fluoride.Mg/l	0.5	Hardness. Mg/l	106	Iron. Mg/l	0.02	Nitrate.Mg/l												
	Well																			
<b>Date</b>	5/7/2020																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	38	24	14	130																
Well # 8																				
Well # 9	32	24	8	110																
Well # 10	32	10	22	120																
Test Well																				
<b>Water Meters</b>	New Installs			Read In																
	Replace Meter			Read Out																
	Replace Radlo			Shut off For nonpayment																
	Read																			
	Repair																			
<b>Fire Hydrants</b>	New Install			Flush Hyd	yes	Repair Hyd														
<b>Water Plant</b>	5/11/20 - Backwashed Filter 1-2-3																			
<b>Water Tower</b>																				
<b>Reservoir</b>																				
<b>Dist. System</b>	5/12/20 - Water main break 6" main Northside of water tower. 5/15/20 - Water main break 6" main Northside of water tower. 15ft west of 5/12 break 5/19 - 5/20 - Replaced 120ft of 6" water main on Northside of water tower. Flushed fire hydrants throughout month. Flow testing SE quadrant of town																			
<b>Wells</b>	5/7/20 - Tested wells 7-9-10 no issues																			
<b>Other</b>																				