

Monthly Water Report

Date	19-Nov																			
Water Plant																				
Total Gal.>	3,374,200	Max	148,500	Min	64,500	Avg	112,500	Gpm	248											
Total Hrs.>	227.8	Max	10.3	Min	4.3	Avg	7.6													
Last Month.>	4,645,500	Max	231,700	Min	87,700	Avg	149,900	Gpm	249											
Last Year.>	3,775,800	Max	252,500	Min	800	Avg	125,900	Gpm	260											
Lbs. of Chlorine 474 Lbs of Fluoride 31 Gallons of salt brine 1,483																				
Chlorine.Mg/l	0.63	Fluoride.Mg/l	0.5	Hardness. Mg/l	96	Iron. Mg/l	0.01	Nitrate.Mg/l												
Well																				
Date	11/25/2019																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	32	18	14	120																
Well # 8																				
Well # 9	34	22	12	160																
Well # 10	24	8	16	90																
Test Well																				
Water Meters																				
	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radlo				Shut off For nonpayment															
	Read																			
	Repair																			
Fire Hydrants																				
	New Install				Flush Hyd				Repair Hyd											
Water Plant																				
	11/7/2019 - Backwashed Filter 1																			
	11/13/2019 - Backwashed Filter 2																			
Water Tower																				
Reservoir																				
Dist. System																				
Wells																				
	11/25/19 - Tested Wells 7-9-10. Well 10 gpm were down, called Northway to have them clean.																			
Other																				