

12/3/2020

Monthly Water Report

2:40 PM

Date	Nov-20											
Water Plant												
Total Gal.>	4,069,900	Max	181,200	Min	108,600	Avg	135,700	Gpm	257			
Total Hrs.>	264.3	Max	12	Min	6.7	Avg	8.81					
Last Month.>	4,344,100	Max	187,300	Min	68,300	Avg	140,100	Gpm	240			
Last Year.>	3,374,200	Max	148,500	Min	64,500	Avg	112,500	Gpm	248			
Lbs.of Chlorine 535 Lbs of Fluoride 36 Gallons of salt brine 1,810												
Chlorine.Mg/l 0.95 Fluoride.Mg/l 0.5 Hardness. Mg/l 102 Iron. Mg/l 0.15 Nitrate.Mg/l												
Well												
Date	11/19/2020											
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	36	20	16	120								
Well # 9	36	26	10	80								
Well # 10	24	12	12	110								
Well # 11	32	26	8	265								
Water Meters												
	New Installs				Read In							
	Replace Meter				Read Out							
	Replace Radio				Shut off For							
	Repair				nonpayment							
Fire Hydrants												
	New Install				Flush Hyd				Repair Hyd			
Water Plant												
	11/5/20 - Backwashed Filter 1											
	11/10/20 - Backwashed Filter 2											
	11/12/20 - Backwashed Filter 3											
Water Tower												
Reservoir												
Dist. System												
Wells												
	11/4/20 - Well 11 went online											
	11/19/20 - Tested wells 7-9-10-11											
Other												