

11/5/2020

Monthly Water Report

11:37 AM

Date	Oct-20																			
Water Plant																				
Total Gal.>	4,344,100	Max	187,300	Min	68,300	Avg	140,100	Gpm	240											
Total Hrs.>	332.5	Max	18.1	Min	3.2	Avg	10.7													
Last Month.>	4,791,400	Max	272,000	Min	96,000	Avg	159,700	Gpm	241											
Last Year.>	4,645,500	Max	231,700	Min	87,700	Avg	149,900	Gpm	249											
Lbs.of Chlorine	677	Lbs of Fluoride	41	Gallons of salt brine	3,056															
Chlorine.Mg/l	0.72	Fluoride.Mg/l	0.4	Hardness. Mg/l	104	Iron. Mg/l	0.01	Nitrate.Mg/l												
Well																				
Date	10/21/2020																			
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	36	22	14	170																
Well # 8																				
Well # 9	36	26	10	90																
Well # 10	24	10	14	110																
Test Well																				
Water Meters	New Installs				Read In															
	Replace Meter				Read Out															
	Replace Radio				Shut off For															
	Road				nonpayment															
	Repair																			
Fire Hydrants	New Install				Flush Hyd				Repair Hyd											
Water Plant	10/29/20 - Cleaned clearwell out.																			
Water Tower																				
Reservoir	Replaced check valve on both booster pumps.																			
Dist. System																				
Wellis																				
Other																				