

# Monthly Water Report

Date	Sep-19											
<b>Water Plant</b>												
Total Gal.>	5,939,600	Max	241,800	Min	158,200	Avg	198,000	Gpm	246			
Total Hrs.>	407.4	Max	20.7	Min	10.1	Avg	13.58					
Last Month.>	6,310,900	Max	247,600	Min	164,500	Avg	203,600	Gpm	259			
Last Year.>	3,868,700	Max	209,300	Min	45,200	Avg	129,000	Gpm	255			
Lbs.of Chlorine	735	Lbs of Fluoride	56	Gallons of salt brine		4,364						
Chlorine.Mg/l	0.62	Fluoride.Mg/l	0.4	Hardness. Mg/l	92	Iron. Mg/l	0.01	Nitrate.Mg/l				
Well												
Date	9/30/2019											
	S	R	DD	Gpm	S	R	DD	Gpm	S	R	DD	Gpm
Well # 7	36	18	18	130								
Well # 8												
Well # 9	34	24	10	180								
Well # 10	24	8	16	100								
Test Well												
<b>Water Meters</b>	New Installs			Read In								
	Replace Meter			Read Out								
	Replace Radio			Shut off For nonpayment								
	Read											
	Repair											
Fire Hydrants	New Install		Flush Hyd		Repair Hyd							
Water Plant	9/20/2019 - Backwashed filters 1-2-3											
Water Tower												
Reservoir												
Dist. System	9/18 -9/19 Flushed fire hydrants											
Wells	9/30/2019 - Tested wells 7-9-10. No issues. Well 8 not working.											
Other												